



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

KEITH JONES, DIRECTOR

February 7, 2019

System No. 3301099

Advent Christian Conf/So. CA
Camp Maranatha
54162 Maranatha LN
Idyllwild, CA 92349

**CITATION NO. 05_63_19C_005
NITRATE MONITORING VIOLATION
FOR CALENDAR YEAR 2019**

Enclosed is Citation No. 05_63_19C_005 (hereinafter "Citation"), issued to the Camp Maranatha (hereinafter "Camp Maranatha"), public water system. Please note there are legally enforceable deadlines associated with this Citation.

Any repeat violations in the future will be subjected for Camp Maranatha to be billed at the Riverside County LPA (hereinafter "LPA"), hourly rate for the time spent on issuing a Citation. California Health and Safety Code (hereinafter "CHSC"), Section 116577, provides that a public water system must reimburse the LPA for actual costs incurred by the LPA for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation.

Any person who is aggrieved by a citation, order or decision issued under authority delegated to an officer or employee of the LPA under Article 8 (commencing with CHSC, Section 116625) or Article 9 (commencing with CHSC, Section 116650), of the Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4), may file a petition with the State Water Board for reconsideration of the citation, order or decision.

Petitions must be received by the State Water Board within 30 days of the issuance of the citation, order or decision by the officer or employee of the state board. The date of issuance is the date when the Division of Drinking Water mails a copy of the citation, order or decision. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day by 5:00 p.m.

Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact Daisy Ciudad Real of my staff at 951-955-8980 or me at 951-955-8980.

Sincerely,

Matthew Riha

Certified Mail No. 70173040000085608656

cc: State Water Resource Control Board, Division of Drinking Water

Riverside County Environmental Health

LPA 63

Name of Public Water System: Camp Maranatha

Water System No: 3301099

Attention: Advent Christian Conf/So. CA
Camp Maranatha
54162 Maranatha LN
Idyllwild, CA 92349

Issued: 2-7-2019

**CITATION FOR NONCOMPLIANCE WITH
CALIFORNIA HEALTH AND SAFETY CODE, SECTION 116555(a)(1) AND
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64432.1(a)**

**NITRATE AND NITRITE MONITORING VIOLATION
CALENDAR YEAR 2019**

The California Health and Safety Code (hereinafter "CHSC"), Section 116650 authorizes the LPA 63 (hereinafter "LPA"), acting by and through its primacy delegation from the State Water Resources Control Board (State Water Board), to issue a citation to a public water system when the LPA determines that the public water system has violated or is violating the California Safe Drinking Water Act (hereinafter "California SDWA"), (CHSC, Division 104, Part 12, Chapter 4,

commencing with Section 116270), or any regulation, standard, permit, or order issued or adopted thereunder.

The LPA acting by and through its primacy delegation from the State Water Board, hereby issues Citation No. 05_63_19C_005 (hereinafter "Citation"), pursuant to Section 116650 of the CHSC to the Camp Maranatha Public Water System (hereinafter "System"), for violation of CHSC, Section 116555(a) (1) and California Code of Regulations (hereinafter "CCR"), Title 22, Section 64431 Maximum Contaminant Levels (hereinafter "MCL") – Inorganic Chemicals.

STATEMENT OF FACTS

This System is classified as a transient public water system with a population of 30, serving 15 connections.

CHSC, Section 116555(a) (1) requires all public water systems to comply with primary drinking water standards as defined in CHSC, Section 116275(c). Primary drinking water standards include maximum levels of contaminants and the monitoring and reporting requirements as specified in regulations adopted by the LPA that pertain to maximum contaminant levels.

Pursuant to CCR, Title 22, Section 64432.1(a), the System is required to collect one sample annually for nitrate and one sample every three years for nitrite testing from each source. During the Calendar Year 2018 compliance period, the System failed to collect a nitrate and a nitrite sample from well #2, Primary Station Code: 3301099-007.

DETERMINATION

The LPA has determined that the System has failed to comply with primary drinking water standards pursuant to CHSC, Section 116555(a) (1) and nitrate and nitrite monitoring requirements pursuant to CCR, Title 22, Sections 64432.1(a).

DIRECTIVES

The System is hereby directed to take the following actions:

1. On or before **2/22/2019** notify all persons served by the System of the violation of CCR, Title 22, Section 64432.1(a), in conformance with Sections 64463.4(b) and (c) and 64465. Appendix 1: Notification Template shall be used to fulfill this Directive.

Notification Template shall be approved by the LPA prior to issuance. **The System must edit the wording of the sample notification as necessary.** The notification shall be completed in accordance with the following:

Posting of the Public Notification in conspicuous places within the area served by the water system. The notice shall remain posted for a minimum of seven (7) consecutive days.

1. Complete Appendix 3: Compliance Certification Form. Submit it together with a copy of the public notification required by Directive 1 to the LPA on or before **3/7/2019**.

2. The system shall ensure that monitoring is conducted annually for nitrate and every 3 years for nitrite from well #2. The system must request that the laboratory, which conducts the analysis, submits the analytical results electronically by a LPA approved method no later than the 10th day of the month following completion of the analyses. The results must also be EDT.

The system shall collect and report the 2019 annual nitrate and the 2019 triannual nitrite sample result from well #2 by **2/28/2019**.

3. On or before **3/7/2019** complete and return to the LPA the "Notification of Receipt" form attached to this Citation as Appendix 3. Completion of this form confirms that the system has received this Citation and understands that it contains legally enforceable directives(s) with due dates.

1 All submittals required by this Citation, with exception of analytical results, shall be electronically
2 submitted to the LPA at the following address. The subject line for all electronic submittals
3 corresponding to this Citation shall include the following information: Water System name and
4 number, citation number and title of the document being submitted.

5 dcidadr@rivco.org

6 The LPA reserves the right to make modifications to this Citation as it may deem necessary to
7 protect public health and safety. Such modifications may be issued as amendments to this Citation
8 and shall be effective upon issuance.

9
10 Nothing in this Citation relieves the system of its obligation to meet the requirements of the California
11 SDWA (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any
12 regulation, standard, permit or order issued or adopted thereunder.

13 14 **PARTIES BOUND**

15 This Citation shall apply to and be binding upon the system, its owners, shareholders, officers,
16 directors, agents, employees, contractors, successors, and assignees.

17 **SEVERABILITY**

18 The directives of this Citation are severable, and the system shall comply with each and every
19 provision thereof notwithstanding the effectiveness of any provision.

20 21 **FURTHER ENFORCEMENT ACTION**

22 The California SDWA authorizes the LPA reference, pursuant to authority delegated by the State
23 Water Board, to: issue a citation or order with assessment of administrative penalties to a public
24 water system for violation or continued violation of the requirements of the California SDWA or any
25 regulation, permit, standard, citation, or order issued or adopted thereunder including, but not
26 limited to, failure to correct a violation identified in a citation or compliance order. Pursuant to its
27 delegated authority, the California SDWA also authorizes the LPA to take action to suspend or
28 revoke a permit that has been issued to a public water system if the public water system has violated

1 applicable law or regulations or has failed to comply with a citation or order of the LPA, and to
2 petition the superior court to take various enforcement measures against a public water system that
3 has failed to comply with a citation or order of the LPA. The LPA does not waive any further
4 enforcement action by issuance of this Citation.

5 
6 _____

7 Matthew Riha

2/7/19

8 Date

9 Appendices 3:

- 10 1. Notification Template
11 2. Compliance Certification Form
12 3. Notification of Receipt Form
13
14

15 Certified Mail No:7017304000008560865